

**Asbestos Hazard Emergency Response Act
Six-Month Asbestos Periodic Surveillance**

Inspection Date: September 15, 2023

COPY

**Plainville Board of Education
Plainville Municipal Center
One Central Square
Plainville, Connecticut**

**For Compliance with
State of Connecticut, Department of Public Health
Regulation Regarding Asbestos-Containing Material in Schools
(19a - 333-1 through 19a - 333-13)
and
The EPA Asbestos Hazard Emergency Response Act
(AHERA, Title 40 CFR Part 763)**

**Plainville High School
47 Robert Holcomb Way
Plainville, Connecticut**

Report Date: September 15, 2023

**Eagle Environmental, Inc.
8 South Main Street, Suite 3
Terryville, Connecticut**

INTRODUCTION

Eagle Environmental, Inc. (Eagle) was retained by Archdiocese of Hartford to conduct Six-Month Periodic Surveillances of asbestos-containing building materials (ACBM) at Plainville High School located at 47 Robert Holcomb Way in Plainville, Connecticut. This surveillance was conducted in accordance with the requirements of the State of Connecticut Department of Public Health (CT DPH) Asbestos-Containing Material in Schools Regulation Sections 19a-333-1 through 19a-333-13 and, United States Environmental Protection Agency (USEPA) Asbestos Hazard Emergency Response Act (AHERA) Regulation (Title 40 CFR Part 763).

Mr. Michael Stewart performed the periodic surveillance on September 15, 2023. This surveillance was based on the information available in the existing Asbestos Management Plan (AMP) for this school. Mr. Peter Folino, a CT DPH licensed Asbestos Inspector/Management Planner (license #000184) developed the response actions contained within this report.

SCOPE OF WORK

The Six-Month Periodic Surveillance involves the visual reassessment of ACBM or assumed ACBM listed in the AMP for the school. The periodic surveillance may be performed by any person knowledgeable in the assessment of ACBMs but does not require State licensure. Functional spaces are accessed to the extent feasible to locate and assess the ACBMs. The assessment is visual in nature and classifies the condition of each ACBM and assumed ACBM as “Good”, “Damaged” or “Significantly Damaged”. The friability of each ACBM and assumed ACBM is also documented. The assessment information is provided on the attached Periodic Surveillance form. Once the materials are assessed, Eagle’s licensed Asbestos Management Planner assigns the recommended response actions for each ACBM or assumed ACBM based on the ACBM condition, accessibility and potential for future damage.

AHERA only covers interior ACBM. Exterior ACBM, such as roofing materials and exterior window caulk/glazing compound are generally not covered under AHERA and were not assessed.

DISCUSSION

Eagle performed the Six-Month Periodic Surveillance and visual reassessment of ACBM or assumed ACBM as listed in the AMP for Plainville High School. Eagle observed that the conditions of the ACBMs have not changed since the last Six-Month Periodic Surveillance. The locations and the most recent conditions of the ACBM or assumed ACBM are listed on the attached Periodic Surveillance Form. Continue to manage the ACBM and assumed ACBM that are in good condition under the school’s O&M program.

Not all ACBMs on the periodic surveillance log are confirmed to be asbestos-containing. The school may want to consider sampling the assumed ACBMs to definitively classify them as an ACBM or Non-ACBM prior to performing response actions. This may alleviate cost of completing some response actions and the continued management of materials that are assumed to be an ACBM.


CONCLUSION

The Local Education Agency (LEA) should continue to manage the ACBMs and/or assumed ACBM’ under the school’s O&M program.

This report and associated assessment information should be used for compliance with AHERA and CT DPH ACBM management only. This report should not be used as a pre-renovation or


RADON TEST KEY:

2584474  =RADON TESTING LOCATION AND NUMBER



SIDE-B  SIDE-C 

(DUPLICATE) 2553624



PLAINVILLE HIGH SCHOOL

NOT TO SCALE

SIDE-A (STREET SIDE) 




EAGLE Environmental, Inc.
 8 SOUTH MAIN STREET, SUITE 3
 TERRYVILLE, CONNECTICUT 06786
 860-589-8257

5 YEAR RADON RE-TESTING
 PLAINVILLE COMMUNITY SCHOOLS
 PLAINVILLE HIGH SCHOOL
 47 ROBERT HOLCOMB WAY
 PLAINVILLE, CONNECTICUT

DATE: 12/14/2017
 PROJECT NO.: 17-041.14TTI
 DRAWN BY: BB
 REVIEWED BY: AR

SHEET NO.
SL-1
 SHEET 1 OF 1

\\eagle\vpublic\2017 files\2017 autocad\plainville public schools\plainville high schools\5-year radon\cad47_radon\cad47_radon\cad47.dwg



STATE OF CONNECTICUT
DEPARTMENT OF PUBLIC HEALTH

PURSUANT TO THE PROVISIONS OF THE GENERAL STATUTES OF CONNECTICUT
 THE INDIVIDUAL NAMED BELOW IS CERTIFIED
 BY THIS DEPARTMENT AS A
ASBESTOS CONSULTANT-INSPECTOR

ANGELO R FOLINO

CERTIFICATE NO.
001163

CURRENT THROUGH
01/31/24

VALIDATION NO.
03-049246

SIGNATURE

COMMISSIONER

COPY

**Asbestos Hazard Emergency Response Act
Six-Month Asbestos Periodic Surveillance**

Inspection Date: September 15, 2023

**Plainville Board of Education
Plainville Municipal Center
One Central Square
Plainville, Connecticut**

**For Compliance with
State of Connecticut, Department of Public Health
Regulation Regarding Asbestos-Containing Material in Schools
(19a - 333-1 through 19a - 333-13)
and
The EPA Asbestos Hazard Emergency Response Act
(AHERA, Title 40 CFR Part 763)**

**Louis Toffolon School
145 Northwest Drive
Plainville, Connecticut**

Report Date: September 15, 2023

**Eagle Environmental, Inc.
8 South Main Street, Suite 3
Terryville, Connecticut**

INTRODUCTION

Eagle Environmental, Inc. (Eagle) was retained by Plainville Board of Education to conduct Six-Month Periodic Surveillances of asbestos-containing building materials (ACBM) at Louis Toffolon School located at 145 Northwest Drive in Plainville, Connecticut. This surveillance was conducted in accordance with the requirements of the State of Connecticut Department of Public Health (CT DPH) Asbestos-Containing Material in Schools Regulation Sections 19a-333-1 through 19a-333-13 and, United States Environmental Protection Agency (USEPA) Asbestos Hazard Emergency Response Act (AHERA) Regulation (Title 40 CFR Part 763).

Mr. Michael Stewart performed the periodic surveillance on September 15, 2023. This surveillance was based on the information available in the existing Asbestos Management Plan (AMP) for this school. Mr. Pete Folino, a CT DPH licensed Asbestos Inspector/Management Planner (license #000184) developed the response actions contained within this report.

SCOPE OF WORK

The Six-Month Periodic Surveillance involves the visual reassessment of ACBM or assumed ACBM listed in the AMP for the school. The periodic surveillance may be performed any person knowledgeable in the assessment of ACBMs but does not require State licensure. Functional spaces are accessed to the extent feasible to locate and assess the ACBMs. The assessment is visual in nature and classifies the condition of each ACBM and assumed ACBM as “Good”, “Damaged” or “Significantly Damaged”. The friability of each ACBM and assumed ACBM is also documented. The assessment information is provided on the attached Periodic Surveillance form. Once the materials are assessed, Eagle’s licensed Asbestos Management Planner assigns the recommended response actions for each ACBM or assumed ACBM based on the ACBM condition, accessibility and potential for future damage.

AHERA only covers interior ACBM. Exterior ACBM, such as roofing materials and exterior window caulk/glazing compound are generally not covered under AHERA and were not assessed.

DISCUSSION

Eagle performed the Six-Month Periodic Surveillance and visual reassessment of ACBM or assumed ACBM as listed in the AMP for Louis Toffolon School. Eagle observed that the conditions of the ACBMs have not changed since the last Six-Month Periodic Surveillance. The locations and the most recent conditions of the ACBM or assumed ACBM are listed on the attached Periodic Surveillance Form. Continue to manage the ACBM and assumed ACBM that are in good condition under the school’s O&M program.

Not all ACBMs on the periodic surveillance log are confirmed to be asbestos-containing. The school may want to consider sampling the assumed ACBMs to definitively classify them as an ACBM or Non-ACBM prior to performing response actions. This may alleviate cost of completing some response actions and the continued management of materials that are assumed to be an ACBM.

CONCLUSION

The Local Education Agency (LEA) should continue to manage the ACBMs and/or assumed ACBM’ under the school’s O&M program.

This report and associated assessment information should be used for compliance with AHERA


TABLE B: FUNCTIONAL SPACES


Building Name: Louis Toffolon Elementary School		Date of Inspection: September 15, 2023	
Building Address: 145 Northwest Drive, Plainville, Connecticut		Project Number: 23-004.13T3	
Local Education Agency (LEA): Plainville Community Schools		Designated Person: Mr. Michael Smith	
Agency (LEA): 1 Central Square, Plainville, Connecticut		Inaccessible Areas: Behind walls and above ceilings	

ACBM Location(s)	Asbestos Containing Building Materials	Material Category	Friability (F/NF)	Previous Condition	Current Condition	Change in Condition (YES/NO)	Total Quantity (SF/LE)	Quantity Damaged (SF/LE)	AHERA Assessment Category	Comments / Response Actions
Throughout	Inaccessible Pipe Insulation and Mudded Fittings	TSI	F	G	G	No	NQ	N/A	5	Manage under O&M Procedures
	Transite®	MISC	NF	G	G	No	NQ	N/A	5	Manage under O&M Procedures
	Vapor Barrier Between Walls	MISC	NF	G	G	No	NQ	N/A	5	Manage under O&M Procedures

KEY


Material Category Codes: TSI = Thermal System Insulation, SURF = Surfacing, MISC = Miscellaneous
Condition Codes: G = Good, D = Damaged, SD = Significantly Damaged

Inspector's Name: Michael Stewart
Inspector's Signature: 
Accreditation #/State: 000305/CT
Expiration Date: October 31, 2023

Management Planner Name: Peter Folino
Management Planner Signature: 
Accreditation #/State: 00084/CT
Expiration Date: May 31, 2024

I, the LEA's Designated Person, have read and understood the recommendations made above:

Signature _____ Date _____



STATE OF CONNECTICUT
DEPARTMENT OF PUBLIC HEALTH

PURSUANT TO THE PROVISIONS OF THE GENERAL STATUTES OF CONNECTICUT
THE INDIVIDUAL NAMED BELOW IS CERTIFIED
BY THIS DEPARTMENT AS A
ASBESTOS CONSULTANT-INSPECTOR

ANGELO R FOLINO

CERTIFICATE NO.
001163

CURRENT THROUGH
01/31/24

VALIDATION NO.
03-049246

Angelo Folino
SIGNATURE

Maureen J. Quinn
COMMISSIONER

**Asbestos Hazard Emergency Response Act
Six-Month Asbestos Periodic Surveillance**

COPY

Inspection Date: September 15, 2023

**Plainville Board of Education
Plainville Municipal Center
One Central Square
Plainville, Connecticut**

**For Compliance with
State of Connecticut, Department of Public Health
Regulation Regarding Asbestos-Containing Material in Schools
(19a - 333-1 through 19a - 333-13)
and
The EPA Asbestos Hazard Emergency Response Act
(AHERA, Title 40 CFR Part 763)**

**Frank T. Wheeler School
15 Cleveland Memorial Drive
Plainville, Connecticut**

Report Date: September 15, 2023

**Eagle Environmental, Inc.
8 South Main Street, Suite 3
Terryville, Connecticut**

INTRODUCTION

Eagle Environmental, Inc. (Eagle) was retained by Plainville Board of Education to conduct Six-Month Periodic Surveillances of asbestos-containing building materials (ACBM) at the Frank T. Wheeler School located at 15 Cleveland Memorial in Plainville, Connecticut. This surveillance was conducted in accordance with the requirements of the State of Connecticut Department of Public Health (CT DPH) Asbestos-Containing Material in Schools Regulation Sections 19a-333-1 through 19a-333-13 and, United States Environmental Protection Agency (USEPA) Asbestos Hazard Emergency Response Act (AHERA) Regulation (Title 40 CFR Part 763).

Mr. Michael Stewart performed the periodic surveillance on September 25, 2023. This surveillance was based on the information available in the existing Asbestos Management Plan (AMP) for this location. Mr. Peter Folino, a CT DPH licensed Asbestos Inspector/Management Planner (license #000184) developed the response actions contained within this report.

SCOPE OF WORK

The Six-Month Periodic Surveillance involves the visual reassessment of ACBM or assumed ACBM listed in the AMP for the school. The periodic surveillance may be performed any person knowledgeable in the assessment of ACBMs but does not require State licensure. Functional spaces are accessed to the extent feasible to located and assess the ACMBs. The assessment is visual in nature and classifies the condition of each ACBM and assumed ACBM as “Good”, “Damaged” or “Significantly Damaged”. The friability of each ACBM and assumed ACBM is also documented. The assessment information is provided on the attached Periodic Surveillance form. Once the materials are assessed, Eagle’s licensed Asbestos Management Planner assigns the recommended response actions for each ACBM or assumed ACBM based on the ACBM condition, accessibility and potential for future damage.

AHERA only covers interior ACBM. Exterior ACBM, such as roofing materials and exterior window caulk/glazing compound are generally not covered under AHERA and were not assessed.

DISCUSSION


Eagle performed the Six-Month Periodic Surveillance and visual reassessment of ACBM or assumed ACBM as listed in the AMP for the Frank T. Wheeler School. Eagle observed that the conditions of the ACBMs have not changed since the last Six-Month Periodic Surveillance. The locations and the most recent conditions of the ACBM or assumed ACBM are listed on the attached Periodic Surveillance Form. Continue to manage the ACBM and assumed ACBM that are in good condition under the school’s O&M program.


Not all ACBMs on the periodic surveillance log are confirmed to be asbestos-containing. The school may want to consider sampling the assumed ACBMs to definitively classify them as an ACBM or Non-ACBM prior to performing response actions. This may alleviate cost of completing some response actions and the continued management of materials that are assumed to be an ACBM.

CONCLUSION

The Local Education Agency (LEA) should continue to manage the ACBMs and/or assumed ACBM’ under the school’s O&M program.

This report and associated assessment information should be used for compliance with AHERA



KEY	
	=KITCHEN AREA



8 SOUTH MAIN STREET, SUITE 3
TERRYVILLE, CONNECTICUT 06786
860-589-8257

SHEET NO.

FP-1

SHEET 1 OF 1

DATE: 4/7/2017
PROJECT NO.: 17-041.11T2
DRAWN BY: BB
REVIEWED BY: AR

3- YEAR AHERA
WHEELER ELEMENTARY SCHOOL
15 CLEVELAND MEMORIAL DRIVE
PLAINVILLE, CONNECTICUT

ATLAS

CERTIFICATE OF ACHIEVEMENT

This certifies that

Michael Stewart

has successfully completed the
4 Hour Asbestos Site Inspector Refresher Training
Asbestos Accreditation Under TSCA Title II
40 CFR Part 763

Training held via a Live
Webinar

Score: 96%

conducted by:

ATC Group Services LLC dba ATLAS Technical
 73 William Franks Drive
 West Springfield, MA 01089
 (413) 781-0070

Gregory J. Morach

Gregory J. Morach

Principal Instructor: Gregory Morach

Regional Training Director: Gregory Morach

April 20, 2023
Date of Course

SIAR - 7401
Certificate Number

April 20, 2024
Expiration Date

April 20, 2023
Examination Date

License Type	License Number	Expiration Date	Granted Date	License Name	License Status		Licensure Actions or Pending Charges
Asbestos Consultant-Inspector	305	10/31/2024	01/30/1998	MICHAEL S. STEWART	ACTIVE	CURRENT	None

CERT#: A-508-Virtual,628

CHEMSCOPE TRAINING DIVISION
ASBESTOS INSPECTOR/MANAGEMENT PLANNER REFRESHER
8-HOUR TRAINING CERTIFICATE

Peter J. Folino

8 South Main Street, Suite 3, Terryville CT


Has attended an 8-hour course on the subject discipline on
09/02/2022 and has passed a written examination.

"The person receiving this certificate has completed the requisite training required for asbestos accreditation as an inspector/management planner under TSCA Title II"

Course topics include a review and update on asbestos health hazards, functions of inspectors and management planners, building systems, planning, inspecting for asbestos, sampling and analysis, respiratory protection, government regulations and preparing the inspection report.

The training course has been accredited by the State of Connecticut.

Examination 1 Score: 98%
Examination 2 Score: 98%
Exam Date: 09/02/2022
Expiration Date: 09/02/2023



Danjel Sullivan
Training Manager

Chem Scope, Inc.
15 Moulthrop Street
North Haven CT 06473
Phone: 203.865.5605
www.chem-scope.com

STATE OF CONNECTICUT

DEPARTMENT OF PUBLIC HEALTH

PURSUANT TO THE PROVISIONS OF THE GENERAL STATUTES OF CONNECTICUT

THE INDIVIDUAL NAMED BELOW IS CERTIFIED
BY THIS DEPARTMENT AS A

ASBESTOS CONSULTANT-INSP/MGMT PLANNER

PETER J. FOLINO

CERTIFICATE NO.
000184

CURRENT THROUGH
05/31/24

VALIDATION NO.
03-042006


SIGNATURE
COMMISSIONER